Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QW368

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PAULUS, JERRY	Phone #: (715)866-4134
Mailing Address: PO BOX 368	
City: WEBSTER	State: WI — Zip Code: 54893
County: Burnett	Co. Permit #: — Notification #: — Completed: 11-07-2003
Well Constructor (Business Name): WEBSTER HARDWARE HANK INC	Lic. #: 6033 — Facility ID # (Public Wells):
Address: PO BOX 130 WEBSTER WI 54893	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 3.5

1. Well Location

Town of OAKLAND			Fire # (if avail.): 27387
Street Address or Road Name and Number: 27387 STONEGATE RD			
Subdivision Name: V2P242	Lot #: 1	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
or Govt Lot #: 2	Section: 33	Township: 40 N	Range: 16 W

2. Well Type New Well
of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	66

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	Y	M	BROWN SILT, SAND, GRAVE, COBBLES	Surface	28
R	S	C	-	SOFT RED CLAY	28	32
R	H	C	-	HARD RED CLAY	32	36
R	S	C	S	SOFT SANDY RED CLAY	36	54
T	Q	S	-	SOFT, CAVING FINE BRN SAND	54	66

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	IPSCO STEEL USA ASTM A53 4.5 X .237 10.79#/FT WELDED JOINTS	Surface	62
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	T JOHNSON CONTINUOUS SLOT SS 10 SLOT	62	66

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level
34 ft. below ground surface

10. Pump Test
Pumping level 39.5 ft. below surface
Pumping at 19 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
WSA		
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		86
Building Overhang		26

Type	Qualifier	Distance
Sewer - Building Sanitary		41
Septic or Holding, or POWTS Tank		64

Comment:

Created On: 12-10-2003 Updated On: 12-10-2003 Review Status: