

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QW368		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner PAULUS, JERRY				Phone # (715)866-4134		1. Well Location				Fire # (if avail.)	
Mailing Address PO BOX 368						Town of OAKLAND				27387	
City WEBSTER				State WI		Zip Code 54893				Street Address or Road Name and Number	
27387 STONEGATE RD						Subdivision Name				Lot #	
V2P242						Block #				1	
Well Constructor (Business Name) WEBSTER HARDWARE HANK INC				Lic. # 6033		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)	
Address PO BOX 130 WEBSTER WI 54893				Well Plan Approval #		°N °W				Method Code	
Approval Date (mm-dd-yyyy)						Section Township Range				or Govt Lot # 2 33 40 N 16 W	
Hicap Permanent Well #				Common Well #		Specific Capacity 3.5				2. Well Type New Well	
3. Well serves 1 # of				Hicap Well ? No		of previous unique well #				constructed in	
Private, potable				Hicap Property ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled	
Heat Exchange ___ # of drillholes				Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
4		Surface		66							
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
T	-	Y	M	BROWN SILT, SAND, GRAVE, COBBLES		Surface		28			
R	S	C	-	SOFT RED CLAY		28		32			
R	H	C	-	HARD RED CLAY		32		36			
R	S	C	S	SOFT SANDY RED CLAY		36		54			
T	Q	S	-	SOFT, CAVING FINE BRN SAND		54		66			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
4		IPSCO STEEL USA ASTM A53 4.5 X .237 10.79#/FT WELDED JOINTS				Surface		62			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
4		T JOHNSON CONTINUOUS SLOT SS 10 SLOT				62		66			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE		Surface				1 S					
9. Static Water Level											
34 ft. below ground surface											
10. Pump Test											
Pumping level 39.5 ft. below surface											
Pumping at 19 GP M for 1 Hrs.											
Pumping Method ?											
11. Well Is											
16 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ?											
Filled & Sealed Well(s) as needed? No											
NONE											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
WSA											
Drill Rig Operator		Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		86	Sewer - Building Sanitary		41
Building Overhang		26	Septic or Holding, or POWTS Tank		64

Comment:

Created On: 12-10-2003

Updated On: 12-10-2003

Review Status: