

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QW375		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner NELSON, CHARMAINE						Phone # (912)429-5021		1. Well Location				Fire # (if avail.) 27216											
Mailing Address PO BOX 14373						Town of OAKLAND						Street Address or Road Name and Number 27216 RON EMERY LN											
City SAVANNAH			State GA		Zip Code 31416		Subdivision Name COLTER SUB				Lot # 2		Block # 2										
County Burnett		Co. Permit #		Notification #		Completed 04-26-2004		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code											
Well Constructor (Business Name) WEBSTER HARDWARE HANK INC				Lic. # 6033		Facility ID # (Public Wells)		SE SE Section Township Range or Govt Lot # 34 40 N 16 W		2. Well Type New Well													
Address PO BOX 130 WEBSTER WI 54893				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # constructed in															
Hicap Permanent Well #			Common Well #			Specific Capacity			Reason for replaced or reconstructed well ?														
3. Well serves 1 # of						Hicap Well ? No		Private, potable															
Heat Exchange ___ # of drillholes						Hicap Property ? No		Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE						Construction Type Driven Point																	
5. Drillhole Dimensions and Construction Method												8. Geology											
Upper Enlarged Drillhole Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Lower Open Bedrock												Geology Codes - - Y - Type, Caving/Noncaving, Color, Hardness, etc... SAND & GRAVEL From (ft.) Surface To (ft.) 42											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Removed? ___ depth ft. (If NO explain on back side)												28 ft. below ground surface				12 in. above grade							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes									
2.5		WHITEWATER J1C2114161 PITLESS ADAPTER				5.5		5.5		Pumping level 28 ft. below surface				Disinfected ? Yes									
2		WHEATLAND USA ASTM A53 2 INCH IPS X .154 WALL 3.75#/FT THREADED & COUPLED				Surface		38		Pumping at 7 GP M for 1 Hrs.				Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?				12. Notified Owner of need to fill & seal ?									
2		60 GA SIMMONS #1753-1 STAINLESS				38		42		Filled & Sealed Well(s) as needed?				No									
7. Grout or Other Sealing Material												13. Constructor / Supervisory Driller				Lic #		Date Signed					
Method MOUNDED												WA				05-27-2004		Drill Rig Operator		Lic or Reg #		Date Signed	
Kind of Sealing Material						From (ft.)		To (ft.)		# Sacks Cement		NONE											
GRANULATED BENTONITE						Surface		0.5 S		0.5 S													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		93	Sewer - Building Sanitary		9
Building Overhang		3	Septic or Holding, or POWTS Tank		82

Comment:

Created On: 10-15-2004

Updated On: 10-15-2004

Review Status: