Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QX126

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: YODER, PHILLIP	Phone #: (608)386-2400
Mailing Address: E3115 CO HWY 154	
City: HILLPOINT	State: WI — Zip Code: 53937-
County: Sauk	Co. Permit #:
Notification #: 19819609	Completed: 08-10-2005
Well Constructor (Business Name): ALBIN R HERBECK	Lic. #: 482
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: AL HERBECK WELL DRILLING, SEXTONVILLE WI 53584-0037	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity	

1. Well Location

Town of WASHINGTON

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NW or Govt Lot #	NW	Section	Township	Range
		29	11 N	3 E

2. Well Type New Well

of previous unique well #

constructed in

Reason for replaced or reconstructed well ?

NEED WATER

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	82
6	82	156

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Yes Cable-tool Bit 6in. dia... No

Dual Rotary .....

Yes Temp. Outer Casing 10in. dia

Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	2
-	-	C	-	CLAY	2	33
-	-	L	-	LIMESTONE	33	64
-	-	N	-	SANDSTONE	64	156

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SCED 40 18:97 PITLESS 6.625 OD ERW SAWHILL USA	Surface	82
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

130 ft. below ground surface

10. Pump Test

Pumping level 130 ft. below surface

Pumping at 10 GP M for 8 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT GROUT	Surface	82	84 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
AH		
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RLG		08-18-2005

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang	>	2

Comment: NO BLDG DRAIN OR BLDG SEWER

Created On: 10-03-2005 Updated On: 11-01-2005 Review Status: