

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QX127		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner MILLER, CALVIN						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address E16503 HWY 82 ST JOH								Town of GREENWOOD				E1650											
City HILLSBORO						State WI		Zip Code 54634				Street Address or Road Name and Number HWY 82 ST JOHNS AVE											
County Vernon		Co. Permit #		Notification # 20205266		Completed 08-29-2005		Subdivision Name				Lot #		Block #									
Well Constructor (Business Name) ALBIN R HERBECK				Lic. # 482		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code											
Address AL HERBECK WELL DRILLING SEXTONVILLE WI 53584-0037				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW SE		Section 6		Township 13 N		Range 1 E									
								or Govt Lot #															
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well															
								of previous unique well # constructed in															
								Reason for replaced or reconstructed well ? NEED WATER															
3. Well serves 1 # of								Hicap Well ? No				Construction Type Drilled											
Private, potable								Hicap Property ? No															
Heat Exchange ___ # of drillholes								Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		92		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				No		- - I -		TOPSOIL		Surface		1					
6		92		230								- - C -		CLAY		1		30					
												- - L -		LIMESTONE		30		45					
												- - N -		SANDSTONE		45		74					
												- - H -		SHALE		74		230					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		180 ft. below ground surface				24 in. above grade									
6		SCED 40 18:97 PE PITLESS 6.625 OD ERW SAWHILL USA				Surface		92		10. Pump Test				Developed ? Yes									
										Pumping level 180 ft. below surface				Disinfected ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 10 GP M for 8 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method TREMIE PUMPED														Filled & Sealed Well(s) as needed? NONE									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed							
CEMENT GROUT				Surface		92		70 S		AH						09-08-2005							
										Drill Rig Operator				Lic or Reg #		Date Signed							
										RPG						09-08-2005							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		50

Comment:

Created On: 10-03-2005

Updated On: 10-03-2005

Review Status: