Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QX127

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MILLER, CALVIN	Phone #
Mailing Address: E16503 HWY 82 ST JOH	
City: HILLSBORO	State: WI / Zip Code: 54634
County: Vernon	Co. Permit #: / Notification #: 20205266 / Completed: 08-29-2005
Well Constructor (Business Name): ALBIN R HERBECK	Lic. #: 482 / Facility ID # (Public Wells):
Address: AL HERBECK WELL DRILLING, SEXTONVILLE WI 53584-0037	Well Plan Approval #: / Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: / Specific Capacity:

1. Well Location

Town of GREENWOOD				Fire # (if avail.): E1650
Street Address or Road Name and Number: HWY 82 ST JOHNS AVE				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code:
SW / SE or Govt Lot #:	Section: 6	Township: 13 N	Range: 1 E	

2. Well Type New Well
of previous unique well #: / constructed in:
Reason for replaced or reconstructed well ?: NEED WATER
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	92
6	92	230

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia... No
- Dual Rotary .....
- Yes Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- - I -	TOPSOIL	Surface	1
- - C -	CLAY	1	30
- - L -	LIMESTONE	30	45
- - N -	SANDSTONE	45	74
- - H -	SHALE	74	230

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SCED 40 18:97 PE PITLESS 6.625 OD ERW SAWHILL USA	Surface	92
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT GROUT	Surface	92	70 S

9. Static Water Level
180 ft. below ground surface

10. Pump Test
Pumping level 180 ft. below surface
Pumping at 10 GP M for 8 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
AH		09-08-2005
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RPG		09-08-2005

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		50

Comment:

Created On: 10-03-2005 Updated On: 10-03-2005 Review Status: