

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QX132		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner PROPP, WILLIAM				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 22447 CO HWY A						Town of RICHLAND				22447	
City RICHLAND CENTER				State WI		Zip Code 53581				Street Address or Road Name and Number	
22447 CO HWY A						Subdivision Name				Lot #	
NEW LANGLE E H						Block #					
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)	
ALBIN R HERBECK				482						°N °W	
Address AL HERBECK WELL DRILLING SEXTONVILLE WI 53584-0037				Well Plan Approval #		SW NW Section Township Range				or Govt Lot #	
				Approval Date (mm-dd-yyyy)		6 10 N 1 E					
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type New Well	
										XQ473 replaces this well	
										of previous unique well # constructed in	
3. Well serves 1 # of				Hicap Well ? No		Reason for replaced or reconstructed well ?				NEED WATER	
Private,potable				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ?		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock								
10 Surface 45			Rotary - Mud Circulation								
6 45 150			Rotary - Air								
			Rotary - Air & Foam								
			Drill-Through Casing Hammer								
			Reverse Rotary								
			Yes Cable-tool Bit 6in. dia... No								
			Dual Rotary								
			Yes Temp. Outer Casing 10in. dia								
			Yes Removed? ___depth ft. (If NO explain on back side)								
8. Geology											
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)		
- - I -			TOPSOIL						Surface 2		
- - C -			CLAY						2 45		
- - N -			SANDSTONE						45 150		
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		SCED 40 18:97 PE PITLESS 6.625 OD ERW SAWHILL USA				Surface		45			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method TREMIE PUMPED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
CEMENT GROUT		Surface		45		18 S					
9. Static Water Level											
40 ft. below ground surface											
10. Pump Test											
Pumping level 40 ft. below surface											
Pumping at 10 GP M for 8 Hrs.											
Pumping Method ?											
11. Well Is											
12 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ?											
Filled & Sealed Well(s) as needed? No											
NONE											
13. Constructor / Supervisory Driller											
Lic #											
Date Signed											
ARH											
Drill Rig Operator											
Lic or Reg #											
Date Signed											
RPG											
06-09-2005											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary	>	12	Sewer - Building Sanitary	>	50
Building Overhang	>	2	Septic or Holding, or POWTS Tank	>	50

Comment:

NEW SAMPLE # DNR ON WELL COMPLETION AND WATER SAMPLE I CHANGED # AS I FORGOT TO INCLUDE PINK SHEET WHEN I REST IN SO I CALLED THEY SAID JUST GO TAKE ANOTHER SAMPLE & [CHANGE DATE?] BECAUSE OF ORIG LOG #QX132. SO THIS IS WHY THE # IS CHANGED. 608/647-4911 IF NEED CALL ME MRS. ALBIN HERBECK PO BOX 37 SECTONVILLE WI

Abandonment Type	Abandonment Date	Procedure	Reason
	10/23/2015	NEAT CEMENT 0-150' 40 SACK USED	IRON CONTAMINANTION

Created On: 09-26-2005

Updated On: 07-11-2023

Review Status: