Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QY223

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CRAIG, GERTRUDE	Phone #
Mailing Address: 8957 STATE RD 162	
City: MINDORO	State: WI — Zip Code: 54644
County: La Crosse	Co. Permit #: 20688 — Notification # — Completed: 01-13-2003
Well Constructor (Business Name): ROY E OINES	Lic. #: 280 — Facility ID # (Public Wells)
Address: 406 WALNUT DR, HOLMEN WI 54636-9605	Well Plan Approval # — Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 0.6

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of BRANS

Fire # (if avail.): N8987

Street Address or Road Name and Number: STATE RD 162

Subdivision Name — Lot # — Block #

Latitude / Longitude in Decimal Degree (DD): 44.0462 °N -90.919 °W
Method Code: GCD013

SW SE or Govt Lot # — Section: 12 — Township: 18 N — Range: 5 W

2. Well Type Replacement
of previous unique well # — constructed in 1971

Reason for replaced or reconstructed well ?
PUMP STUCK IN WELL

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	52
6	52	61

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes — Rotary - Air & Foam ..... — Yes
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	V	S	-	NONCAVING SAND	Surface	13
-	-	N	-	SANDSTONE	13	61

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW P.E. BLACK STEEL WHEATLAND USA 18.97# I80 WALL ASTMA53-B WELD	Surface	52
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PRESSURE TRIMMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	52	10 S

9. Static Water Level
35 ft. below ground surface

10. Pump Test
Pumping level 51 ft. below surface
Pumping at 10 GP for 1.5 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RO		01-13-2003
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JS		01-13-2003

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		94	Sewer - Building Sanitary		52
Building Overhang		16	Septic or Holding, or POWTS Tank		61

Comment:

Created On: 03-05-2003 Updated On: 04-30-2020 Review Status: