

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QY223		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner CRAIG, GERTRUDE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 8957 STATE RD 162								Town of BRANS				N8987	
City MINDORO						State WI		Zip Code 54644				Street Address or Road Name and Number STATE RD 162	
County La Crosse		Co. Permit # 20688		Notification #		Completed 01-13-2003		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) ROY E OINES				Lic. # 280		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.0462 °N -90.919 °W				Method Code GCD013	
Address 406 WALNUT DR HOLMEN WI 54636-9605				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 12 18 N 5 W		2. Well Type Replacement of previous unique well # constructed in 1971 Reason for replaced or reconstructed well ? PUMP STUCK IN WELL Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6									
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
8		Surface		52						Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)			
6		52		61		Rotary - Mud Circulation Rotary - Air <u>Yes</u> Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- V S - NONCAVING SAND Surface 13 - - N - SANDSTONE 13 61			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		NEW P.E. BLACK STEEL WHEATLAND USA 18.97# I80 WALL ASTMA53-B WELD				Surface		52		35 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
										18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material													
Method PRESSURE TRIMMIE													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?					
PORTLAND CEMENT		Surface		52		10 S		Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller													
RO		Lic #		Date Signed 01-13-2003									
Drill Rig Operator		Lic or Reg #		Date Signed 01-13-2003									
JS													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		94	Sewer - Building Sanitary		52
Building Overhang		16	Septic or Holding, or POWTS Tank		61

Comment:

Created On: 03-05-2003

Updated On: 04-30-2020

Review Status: