Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QY225

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CRAIG, CALVIN	Phone #: (608)486-4318
Mailing Address: W215 SAND CREEK RD	
City: MINDORO	State: WI — Zip Code: 54644
County: La Crosse	Co. Permit #: 20689 — Notification #: — Completed: 01-20-2003
Well Constructor (Business Name): ROY E OINES	Lic. #: 280 — Facility ID # (Public Wells):
Address: 406 WALNUT DR, HOLMEN WI 54636-9605	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well # — Specific Capacity: 0.8	

1. Well Location

Town of BRUNS	Fire # (if avail.): W215
Street Address or Road Name and Number: SAND CREEK RD	
Subdivision Name: — Lot #: — Block #:	
Latitude / Longitude in Decimal Degree (DD): 44.0485 °N -90.9177 °W	Method Code: GCD013
NE SE or Govt Lot #: — Section: 12 — Township: 18 N — Range: 5 W	

2. Well Type Replacement
of previous unique well #: — constructed in: 1970
Reason for replaced or reconstructed well ?: PUMP STUCK IN WELL
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	4
6	4	104

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 6in. dia... — Yes
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	71
-	-	G	-	GRAVEL	71	90
-	-	N	-	SANDSTONE	90	104

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW P.E. BLACK STEEL WHEATLAND USA 18.95# 280 WALL ASTM A53-B WELD	Surface	91
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
56 ft. below ground surface

10. Pump Test
Pumping level 69 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BENTONITE DRIVE THUR

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENONITE	Surface	4	3 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RO		01-20-2003
Drill Rig Operator	Lic or Reg #	Date Signed
JS		01-20-2003

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		62
Building Drain - Sanitary		31

Type	Qualifier	Distance
Building Overhang		10
Sewer - Building Sanitary		36
Septic or Holding, or POWTS Tank		51

Comment:

Created On: 03-05-2003 Updated On: 04-30-2020 Review Status: