

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QZ953		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MCCLARY BUILDERS, SPANGLER, KE						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address E4870 ROLLING HILLS						Town of SPRING GREEN						E4870			
City SPRING GREEN						State WI		Zip Code 53588				Street Address or Road Name and Number E4870 ROLLING RIDGE RD			
County Sauk		Co. Permit #		Notification #		Completed 07-03-2002		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) ROBERT C KOUBA				Lic. # 152		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2289 °N -90.0753 °W				Method Code GCD013	
Address PO BOX 484 HILLSBORO WI 54634				Well Plan Approval #		SE NE		Section 25		Township 9 N		Range 3 E		2. Well Type New Well	
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3				of previous unique well # constructed in					
3. Well serves 1 # of				Hicap Well ? No		Reason for replaced or reconstructed well ?									
Private, potable				Hicap Property ? No		Construction Type Drilled									
Heat Exchange ___ # of drillholes				Hicap Potable ?		Reason for replaced or reconstructed well ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.75		Surface		42		Rotary - Mud Circulation				No					
6		42		385		Yes Rotary - Air				No					
Rotary - Air & Foam						Drill-Through Casing Hammer									
Reverse Rotary						Cable-tool Bit ___ in. dia...									
Dual Rotary						Yes Temp. Outer Casing 10in. dia									
Yes Removed? 8depth ft. (If NO explain on back side)						No									
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology					
6.625		NEW PLAIN END STEEL WELDED IPSCO CASING ASTM A53B 18.97 LBS/FT .280 WALL				Surface		42		Geology Codes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Type, Caving/Noncaving, Color, Hardness, etc...					
6		DRIVE SHOE				From (ft.)		To (ft.)		From (ft.)					
6		DRIVE SHOE				From (ft.)		To (ft.)		To (ft.)					
7. Grout or Other Sealing Material															
Method PRESSURE GROUTED FROM BOTTOM O															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		- - C - CLAY					
NEAT CEMENT				Surface		42		10 S		R - N - RED SANDSTONE					
9. Static Water Level															
300 ft. below ground surface															
10. Pump Test															
Pumping level 365 ft. below surface															
Pumping at 20 GP M for 1 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
RCK								Lic #		Date Signed					
Drill Rig Operator								Lic or Reg #		Date Signed					
07-03-2002								07-03-2002		07-03-2002					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		12

Comment:

Created On: 08-29-2002

Updated On: 03-30-2020

Review Status: