Well Construction Report
WISCONSIN UNIQUE WELL NUMBER QZ961

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PHILLIPS, LORI			Phone #: (608)847-5589
Mailing Address: 723 GROVE ST			
City: MAUSTON	State: WI	Zip Code: 53948	
County: Juneau	Co. Permit #:	Notification #:	Completed: 07-09-2002

Well Constructor (Business Name): ROBERT C KOUBA	Lic. #: 152	Facility ID # (Public Wells):	
Address: PO BOX 484 HILLSBORO WI 54634		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of LINDINA				Fire # (if avail.): N3609
Street Address or Road Name and Number: N3609 HWY G				
Subdivision Name:			Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code:
NE NW or Govt Lot #:	Section: 23	Township: 15 N	Range: 3 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	42
6	42	105

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes Rotary - Air ..... No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? 11depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	10
T	-	N	-	LT BROWN SANDSTONE	10	80
I	-	N	-	WHITE SANDSTONE	80	90
T	-	N	-	LT BROWN SANDSTONE	90	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	NEW PLAIN END STEEL WELDED IPSCO CASING ASTM A53B 18.97LBS/FT .280 WALL	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	DRIVE SHOE		

7. Grout or Other Sealing Material

Method PRESSURE GROUTED FROM BOTTOM O

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	42	13 S

9. Static Water Level
29 ft. below ground surface

10. Pump Test
Pumping level 85 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RCK		07-09-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		12
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 08-08-2002 Updated On: 08-08-2002 Review Status: