

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				QZ961		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner PHILLIPS, LORI						Phone # (608)847-5589		1. Well Location				Fire # (if avail.)					
Mailing Address 723 GROVE ST						Town of LINDINA						N3609					
City MAUSTON						State WI		Zip Code 53948				Street Address or Road Name and Number					
County Juneau						Co. Permit #		Notification #		Completed 07-09-2002		Subdivision Name		Lot #		Block #	
Well Constructor (Business Name) ROBERT C KOUBA						Lic. # 152		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Address PO BOX 484 HILLSBORO WI 54634						Well Plan Approval #		NE NW Section Township Range or Govt Lot # 23 15 N 3 E									
Hicap Permanent Well #						Common Well #		Specific Capacity 0.4		2. Well Type New Well							
Heat Exchange ___ # of drillholes						Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?							
Hicap Potable ?										Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock														
8.75 Surface 42			Rotary - Mud Circulation														
6 42 105			Yes Rotary - Air No														
			Rotary - Air & Foam														
			Drill-Through Casing Hammer														
			Reverse Rotary														
			Cable-tool Bit ___ in. dia...														
			Dual Rotary														
			Yes Temp. Outer Casing 10in. dia														
			Yes Removed? 11depth ft. (If NO explain on back side)														
8. Geology																	
Dia. (in.) From (ft.) To (ft.)			Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)								
8.75 Surface 42			- - S -			SAND			Surface 10								
6 42 105			T - N -			LT BROWN SANDSTONE			10 80								
			I - N -			WHITE SANDSTONE			80 90								
			T - N -			LT BROWN SANDSTONE			90 105								
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6.625		NEW PLAIN END STEEL WELDED IPSCO CASING ASTM A53B 18.97LBS/FT .280 WALL				Surface		42									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
6		DRIVE SHOE															
7. Grout or Other Sealing Material																	
Method PRESSURE GROUTED FROM BOTTOM O																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
NEAT CEMENT				Surface		42		13 S									
9. Static Water Level																	
29 ft. below ground surface																	
10. Pump Test																	
Pumping level 85 ft. below surface																	
Pumping at 20 GP M for 1 Hrs.																	
Pumping Method ?																	
11. Well Is																	
12 in. above grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed?																	
13. Constructor / Supervisory Driller																	
RCK				Lic #		Date Signed											
Drill Rig Operator				Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		12
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 08-08-2002

Updated On: 08-08-2002

Review Status: