

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RA155		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BURG, KEN						Phone # (262)644-8860		1. Well Location				Fire # (if avail.)							
Mailing Address 4075 LOVERS LN								Town of POLK				4075							
City SLINGER						State WI		Zip Code 53086				Street Address or Road Name and Number LOVERS LN							
County Washington		Co. Permit #		Notification #		Completed 08-16-2002		Subdivision Name CSM 5254				Lot # 1		Block #					
Well Constructor (Business Name) ZIELIEKE WELL DRILLING INC				Lic. # 107		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.3382 °N -88.2618 °W				Method Code GCD013					
Address N944 ELMORE DR CAMPBELLSPORT WI 53010				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 17 10 N 19 E				2. Well Type New Well									
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		Reason for replaced or reconstructed well ?				Construction Type Drilled									
3. Well serves 1 # of Private, potable				Hicap Well ? No															
Heat Exchange ___ # of drillholes				Hicap Property ? No															
						Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		315						- - C -		CLAY		Surface		28			
						<u>No</u> Rotary - Air <u>Yes</u>				- - G -		GRAVEL		28		157			
						<u>Yes</u> Rotary - Air & Foam				- - P -		HARDPAN		157		182			
						Drill-Through Casing Hammer				- - C G		GRAVELLY CLAY		182		220			
						Reverse Rotary				- - G -		GRAVEL W/WOOD CHIPS		220		242			
						Cable-tool Bit ___ in. dia...				- B L -		BROKEN LIMESTONE		242		244			
						Dual Rotary				- - L -		LIMESTONE		244		315			
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		169 ft. below ground surface				14 in. above grade					
6		IPSCO A53B 18.97 WELDED				Surface		244		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 205 ft. below surface				Disinfected ? Yes					
										Pumping at 15 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method GRAVITY												Filled & Sealed Well(s) as needed? No NONE ONSITE							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
MOUNDED W/CRUMBLES				Surface															
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												JLZ						08-26-2002	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Downspout/Yard Hydrant		16
Building Drain - Sanitary		27	Foundation Drain to Clearwater		14
Building Overhang		7	Sewer - Building Sanitary		60
Clearwater Sump		16	Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 10-02-2002

Updated On: 07-08-2019

Review Status: