

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RA157		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner RAMTHUN JR, OTTO						Phone # (262)626-2906		1. Well Location				Fire # (if avail.)									
Mailing Address N1953 DD RD						Town of AUBURN						N1953									
City CAMPBELLSPORT						State WI		Zip Code 53010				Street Address or Road Name and Number N1953 DD RD									
County Fond du Lac		Co. Permit #		Notification #		Completed 09-10-2002		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) ZIELIEKE WELL DRILLING INC				Lic. # 107		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.6117 °N -88.2135 °W				Method Code GCD013							
Address N944 ELMORE DR CAMPBELLSPORT WI 53010				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 10 13 N 19 E		2. Well Type New Well				of previous unique well #		constructed in							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		Reason for replaced or reconstructed well ?				Construction Type Drilled											
3. Well serves 1 # of				Hicap Well ? No		Reason for replaced or reconstructed well ?															
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ?		Reason for replaced or reconstructed well ?				Reason for replaced or reconstructed well ?											
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method																					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock											
6		Surface		189		Rotary - Mud Circulation				Rotary - Air											
No		Rotary - Air & Foam		Yes		Drill-Through Casing Hammer				Reverse Rotary											
Yes		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia				Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen																					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology											
6		IPSCO A53B 18.97 WELDED				Surface		146		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		- - C -		CLAY		Surface		2					
6		IPSCO A53B 18.97 WELDED				Surface		146		- - Y -		SAND & GRAVEL		2		116					
6		IPSCO A53B 18.97 WELDED				Surface		146		- - P -		HARDPAN		116		122					
6		IPSCO A53B 18.97 WELDED				Surface		146		- - G -		GRAVEL		122		146					
6		IPSCO A53B 18.97 WELDED				Surface		146		- - L H		LIMESTONE W/SHALE VEINS		146		189					
7. Grout or Other Sealing Material														9. Static Water Level				11. Well Is			
Method GRAVITY														15 ft. below ground surface				18 in. above grade			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test				Developed ? Yes									
MOUNDED W/CRUMBLES		Surface		Surface		Surface		Pumping level 45 ft. below surface				Disinfected ? Yes									
MOUNDED W/CRUMBLES		Surface		Surface		Surface		Pumping at 20 GP M for 1 Hrs.				Capped ? Yes									
MOUNDED W/CRUMBLES		Surface		Surface		Surface		Pumping Method ?				Filled & Sealed Well(s) as needed? No									
12. Notified Owner of need to fill & seal ?														13. Constructor / Supervisory Driller				Lic #		Date Signed	
NONE ONSITE														JLZ				10-09-2002			
Filled & Sealed Well(s) as needed? No														Drill Rig Operator				Lic or Reg #		Date Signed	
NONE ONSITE														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		51	Downspout/Yard Hydrant		30
Building Drain - Sanitary		54	Foundation Drain to Clearwater		29
Building Overhang		29	Wastewater Sump		84
Clearwater Sump		48	Sewer - Building Sanitary		45
			Septic or Holding, or POWTS Tank		34

Comment:

Created On: 01-08-2003

Updated On: 10-08-2019

Review Status: