Well Construction Report
WISCONSIN UNIQUE WELL NUMBER

RA158

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MCCLARREN, WM & LOUISE	Phone #: (262)338-3245
Mailing Address: 1531 N 12TH AVE	
City: WESTBEND	State: WI — Zip Code: 53095
County: Fond du Lac	Co. Permit #: — Notification #: — Completed: 09-25-2002
Well Constructor (Business Name): ZIELIEKE WELL DRILLING INC	Lic. #: 107 — Facility ID # (Public Wells):
Address: N944 ELMORE DR, CAMPBELLSPORT WI 53010	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.1

1. Well Location

Town of ASHFORD	Fire # (if avail.): W4123
Street Address or Road Name and Number: HALLS LN	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.597 °N -88.3631 °W	Method Code: GCD013
SW NW or Govt Lot #:	Section: 16 — Township: 13 N — Range: 18 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	49
6	49	160

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes / No — Rotary - Mud Circulation .....
- No / Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	G	GRAVELLY CLAY	Surface	49
-	-	L	-	LIMESTONE	49	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO A53B 18.97 WELDED	Surface	49
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

62 ft. below ground surface

10. Pump Test

Pumping level 150 ft. below surface

Pumping at 10 GP M for 12 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY & DRILLING MUD	Surface	49	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

WELL USED FOR BARN

13. Constructor / Supervisory Driller	Lic #	Date Signed
JLZ		10-09-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		360
Building Drain - Sanitary		15
Building Overhang		9
Clearwater Sump		70

Type	Qualifier	Distance
Downspout/Yard Hydrant		15
Foundation Drain to Clearwater		10
Sewer - Building Sanitary		70
Septic or Holding, or POWTS Tank		140

Comment:

Created On: 01-08-2003 Updated On: 10-08-2019 Review Status: