

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RB968		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner PECK, RODGER						Phone # (715)790-7274		1. Well Location				Fire # (if avail.) 87975			
Mailing Address PO BOX 22						Town of CLOVER						Street Address or Road Name and Number BARK POINT RD			
City HERBSTER				State WI		Zip Code 54844		Subdivision Name				Lot #		Block #	
County Bayfield		Co. Permit #		Notification #		Completed 09-17-2002		Latitude / Longitude in Decimal Degree (DD) 46.8471 °N -91.2446 °W				Method Code GCD013			
Well Constructor (Business Name) GARY LIND				Lic. # 93		Facility ID # (Public Wells)		SW NW Section Township Range or Govt Lot # 4 50 N 7 W		2. Well Type New Well					
Address RT 1 BOX 73 IRON RIVER WI 54847-9720				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # constructed in							
Hicap Permanent Well #				Common Well #		Specific Capacity 0.5		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 8.75		From (ft.) Surface		To (ft.) 134		Upper Enlarged Drillhole			Lower Open Bedrock						
Yes		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						No							
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
- - C -		CLAY				Surface		45							
- - P -		HARDPAN				45		128							
- - S -		SAND				128		134							
6. Casing, Liner, Screen															
Dia. (in.) 6		Material, Weight, Specification NEW STEEL PIPE PLAIN END A-53-B IPSCO				From (ft.) Surface		To (ft.) 130							
Dia. (in.) 4		Screen type, material & slot size STAINLESS 10 SLOT				From (ft.) 130		To (ft.) 134							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material MUD & DRILL CUTTINGS				From (ft.) Surface		To (ft.) 134		# Sacks Cement							
9. Static Water Level															
81 ft. below ground surface															
10. Pump Test															
Pumping level 100 ft. below surface															
Pumping at 10 GP M for 3 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
GL										09-30-2002					
Drill Rig Operator								Lic or Reg #		Date Signed					
WH										09-30-2002					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 01-31-2003

Updated On: 06-25-2020

Review Status: