Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RB970

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: COSGROVE, BRIDGETT			Phone #: (715)378-2247
Mailing Address: 9708 SCENIC DR			
City: SOLON SPRINGS	State: WI	Zip Code: 54873	
County: Douglas	Co. Permit #:	Notification #:	Completed: 10-01-2002

Well Constructor (Business Name): GARY LIND	Lic. #: 93	Facility ID # (Public Wells):	
Address: RT 1 BOX 73 IRON RIVER WI 54847-9720		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

1. Well Location

Village of SOLON SPRINGS

Fire # (if avail.):

Street Address or Road Name and Number: 3RD ST

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NW NW or Govt Lot #:	Section: 25	Township: 45 N	Range: 12 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6.5	Surface	95

Upper Enlarged Drillhole: Yes

Lower Open Bedrock: No

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	G	-	GRAVEL	Surface	20
-	-	P	-	HARDPAN	20	60
-	-	S	-	SAND	60	95

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW STEEL PIPE PLAIN END A53B IPSCO	Surface	91
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	STAINLESS 10 SLOT	91	95

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD & DRILL CUTTINGS	Surface	95	

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 12 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GL		10-10-2002
Drill Rig Operator	Lic or Reg #	Date Signed
WH		10-10-2002

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		30	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 02-07-2003 Updated On: 02-07-2003 Review Status: