

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RD769		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																					
Property Owner KRUPA, LORETTA						Phone # (608)565-2420		1. Well Location				Fire # (if avail.)																			
Mailing Address N9853 STATE RD 80						Town of NECEDAH						N9853																			
City NECEDAH						State WI		Zip Code 54646				Street Address or Road Name and Number N9853 STATE RD 80																			
County Juneau		Co. Permit #		Notification #		Completed 07-03-2003		Subdivision Name				Lot #		Block #																	
Well Constructor (Business Name) EDWIN D GREENFIELD				Lic. # 615		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0011 °N -90.0718 °W				Method Code GCD013																	
Address W4493 20TH TERRACE NECEDAH WI 54646				Well Plan Approval #		NW SW		Section 30		Township 18 N		Range 4 E		2. Well Type Replacement																	
Hicap Permanent Well #				Common Well #		Specific Capacity 2				of previous unique well # constructed in																					
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ? PLUGGED SAND POINT																					
3. Well serves 1 # of Private, potable				Hicap Potable ?		Construction Type Drilled																									
4. Potential Contamination Sources - ON REVERSE SIDE																															
5. Drillhole Dimensions and Construction Method														8. Geology																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)													
9		Surface		65		Yes Rotary - Mud Circulation No				Rotary - Air		Rotary - Air & Foam		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit ___ in. dia...		Dual Rotary		Temp. Outer Casing ___ in. dia		Removed? ___ depth ft. (If NO explain on back side)		- - S - SAND Surface 8		- N S - FINE SAND 8 60		- A S - COARSE SAND 60 65	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10 ft. below ground surface				12 in. above grade																	
5		SCED 40				Surface		3		10. Pump Test				Developed ? Yes																	
5		SDR21 CLASS 200 PVC 1120 WELL CASING ASTMF480 CERT				3		60		Pumping level 15 ft. below surface				Disinfected ? Yes																	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 10 GP M for 1 Hrs.				Capped ? Yes																	
5		20 SLOT PVC				60		65		Pumping Method ?				12. Notified Owner of need to fill & seal ?																	
7. Grout or Other Sealing Material														Filled & Sealed Well(s) as needed? Yes																	
Method PUMPED TREMIE														13. Constructor / Supervisory Driller																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Lic #				Date Signed																	
BENTONITE GROUT				Surface		55				EG				07-21-2003																	
										Drill Rig Operator				Lic or Reg #				Date Signed													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		15
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 08-19-2003

Updated On: 05-04-2020

Review Status: