Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RE100

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DEMBNY, KEVIN			Phone #: (414)587-6443
Mailing Address: W3779 CO RD C			
City: MONTELLO	State: WI	Zip Code: 53949	
County: Marquette	Co. Permit #:	Notification #:	Completed: 11-11-2003

1. Well Location

Town of MONTELLO

Fire # (if avail.): W3779

Street Address or Road Name and Number: W3779 CO RD C

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ROBERT W SHOWERS	525	

Latitude / Longitude in Decimal Degree (DD): 43.7898 °N -89.3504 °W

Method Code: GCD013

Well Plan Approval #:

SE or Govt Lot #	SE	Section: 7	Township: 15 N	Range: 10 E

Address: BOB SHOWERS WELL DRILLING CO
MONTELLO WI 53949-9203

Approval Date (mm-dd-yyyy):

2. Well Type Replacement

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.2

Reason for replaced or reconstructed well ?: BAD POINT WELL

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	87

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 4in. dia... No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	18
-	-	C	S	SANDY CLAY	18	41
-	-	C	-	CLAY	41	56
-	-	C	S	SANDY CLAY	56	81
-	-	Y	-	SAND & GRAVEL	81	87

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK PLAIN END STEEL 10.79# IPSCO	Surface	83
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	12 SLOT STAINLESS STEEL	83	87

9. Static Water Level

3 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 10 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RWS		12-26-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		7	Sewer - Building Sanitary		17
			Septic or Holding, or POWTS Tank		33

Comment:

Created On: 02-23-2004 Updated On: 04-08-2020 Review Status: