

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RE101		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner KEENA, ROLLIN Phone # (608)586-4527						1. Well Location Fire # (if avail.) 3386					
Mailing Address 3386 CO RD G City OXFORD State WI Zip Code 53952						Town of JACKSON Street Address or Road Name and Number 3386 CO RD G					
County Adams		Co. Permit #		Notification #		Completed 11-21-2003		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) ROBERT W SHOWERS				Lic. # 525		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.7632 °N -89.6585 °W		Method Code GCD013	
Address BOB SHOWERS WELL DRILLING CO MONTELLO WI 53949-9203				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW SW Section Township Range or Govt Lot # 22 15 N 7 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? POINT WELL WENT DRY Construction Type Drilled	
Hicap Permanent Well #		Common Well #		Specific Capacity 10		Hicap Well ? No		Hicap Property ? No		Hicap Potable ?	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						4. Potential Contamination Sources - ON REVERSE SIDE					
5. Drillhole Dimensions and Construction Method						8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)	
4		Surface		85		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit 4in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - S - SAND Surface 38 - - X - SAND & CLAY 38 77 - - Y - SAND & GRAVEL 77 85	
6. Casing, Liner, Screen						9. Static Water Level 52 ft. below ground surface				11. Well Is 15 in. above grade	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		Developed ? Yes Disinfected ? Yes Capped ? Yes	
4		NEW BLACK PLAIN END STEEL 10.79# IPSCO				Surface		81			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
4		12 SLOT STAINLESS STEEL				81		85			
7. Grout or Other Sealing Material Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement Surface						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes					
						13. Constructor / Supervisory Driller		Lic #		Date Signed	
						RWS				12-10-2003	
						Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Sewer - Building Sanitary		31
Building Overhang		6	Septic or Holding, or POWTS Tank		44

Comment:

Created On: 01-20-2004

Updated On: 05-04-2020

Review Status: