Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RE101

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KEENA, ROLLIN			Phone #: (608)586-4527
Mailing Address: 3386 CO RD G			
City: OXFORD	State: WI	Zip Code: 53952	
County: Adams	Co. Permit #:	Notification #:	Completed: 11-21-2003

Well Constructor (Business Name): ROBERT W SHOWERS	Lic. #: 525	Facility ID # (Public Wells):	
Address: BOB SHOWERS WELL DRILLING CO MONTELLO WI 53949-9203		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 10	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.): 3386

Town of JACKSON

Street Address or Road Name and Number: 3386 CO RD G

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.7632 °N	-89.6585 °W			GCD013
SW SW or Govt Lot #	Section: 22	Township: 15 N	Range: 7 E	

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
POINT WELL WENT DRY

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	85

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	38
-	-	X	-	SAND & CLAY	38	77
-	-	Y	-	SAND & GRAVEL	77	85

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK PLAIN END STEEL 10.79# IPSCO	Surface	81
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	12 SLOT STAINLESS STEEL	81	85

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
52 ft. below ground surface

10. Pump Test
Pumping level 53 ft. below surface
Pumping at 10 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RWS		12-10-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Sewer - Building Sanitary		31
Building Overhang		6	Septic or Holding, or POWTS Tank		44

Comment:

Created On: 01-20-2004 Updated On: 05-04-2020 Review Status: