Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RE102

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DAVIS, BILL	Phone #: (608)834-0872
Mailing Address: W4578 CO RD K	
City: MONTELLO	State: WI — Zip Code: 53949
County: Marquette	Co. Permit #: — Notification #: — Completed: 12-04-2003
Well Constructor (Business Name): ROBERT W SHOWERS	Lic. #: 525 — Facility ID # (Public Wells):
Address: BOB SHOWERS WELL DRILLING CO, MONTELLO WI 53949-9203	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of PACKWAUKEE	Fire # (if avail.): W4578
Street Address or Road Name and Number: W4578 HWY K	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.7747 °N -89.3881 °W	Method Code: GCD013
SE SE or Govt Lot #: — Section: 14 — Township: 15 N — Range: 9 E	

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: POINT WELL-DRY

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	137

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	38
-	-	X	-	CLAY & SAND	38	61
-	-	C	-	CLAY	61	132
-	-	Y	-	SAND & GRAVEL	132	137

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ID NEW BLACK PE STEEL 10.79 LB-IPSCO	Surface	133
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	OD 15 SLOT STAINLESS STEEL	133	137

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 82 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RWS		12-25-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		96
Building Overhang		11

Type	Qualifier	Distance
Sewer - Building Sanitary		41
Septic or Holding, or POWTS Tank		72

Comment:

Created On: 02-23-2004 Updated On: 04-08-2020 Review Status: