Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RE486

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KETTLESON, THEODORE	Phone #: (715)258-9619
Mailing Address: 1559 APPLE TREE LN	
City: WAUPACA	State: WI Zip Code: 54981
County: Waupaca	Co. Permit #:
Notification #:	Completed: 08-02-2003
Well Constructor (Business Name): MICHAEL JOHNSON	Lic. #: 545
Facility ID # (Public Wells):	
Address: OGDENSBURG WELL DRILLING, OGDENSBURG WI 54962-9704	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.7	

1. Well Location

Town of LITTLE WOLF	Fire # (if avail.): 600
Street Address or Road Name and Number: SPRUCE ST	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 44.4551 °N -88.931 °W	Method Code: GCD013
SW NE or Govt Lot #:	Section: 21 Township: 23 N Range: 13 E

2. Well Type New Well — YI260 replaces this well of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	10
6	10	38

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia... — No
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? 10depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	-	I	-	BLACK TOPSOIL	Surface	1
I	Q	Y	-	SAND CAVING WHITE SOFT	1	5
G	H	Z	G	CLAY GRAVEL STONES NONCAVING GREY	5	12
T	M	S	-	SAND CAVING TAN SOFT	12	20
R	Q	X	-	SAND LAYERS RED CLAY CAVING SOFT	20	32
I	W	S	-	MED SAND CAVING WHITE SOFT	32	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW SAWHILL T&C R&D ASTMA53 19.45#/FT	Surface	34
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	10 SLOT STAINLESS STEEL JOHNSON KPACKER	34	38

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	10	

9. Static Water Level
13 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 20 GP M for 24 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		08-22-2003
Drill Rig Operator	Lic or Reg #	Date Signed
MJ		08-22-2003

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		25	Downspout/Yard Hydrant		27

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	06/26/2013	3/8 INCH BAROID HOLEPLUG 0-32' 9 SACKS USED	PUMPS SAND/LOW YIELD

Created On: 10-08-2003 Updated On: 05-08-2020 Review Status: