Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RE488

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	WALKUSH, MIKE
Phone #	
Mailing Address	7057 BALSAM RD
City	WAUPACA
State	WI
Zip Code	54981
County	Portage
Co. Permit #	
Notification #	
Completed	08-07-2003
Well Constructor (Business Name)	MICHAEL JOHNSON
Lic. #	545
Facility ID # (Public Wells)	
Address	OGDENSBURG WELL DRILLING OGDENSBURG WI 54962-9704
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	16

3. Well serves 1 # of HOMES
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.)	7057		
Town of LANARK			
Street Address or Road Name and Number	7057 BALSAM RD		
Subdivision Name	CSM 14115 169	Lot # 16	Block #
Latitude / Longitude in Decimal Degree (DD)	44.3575 °N -89.276 °W	Method Code	GCD013
NE NW or Govt Lot #		Section 27	Township 22 N
Range	10 E		

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	1
6	10	78

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia... No
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? 10depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K - I -	BLACK TOP SOIL	Surface	1
T Q S S	MED SAND CAVING BROWN SOFT	1	21
G V Z G	CLAY GRAVEL NONCAVING HARD GRAY	21	39
I W Y -	SAND GRAVEL CAVING WHITE SOFT	39	78

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW SAWHILL T&C R&D ASTM 53 19.45 LB FOOT	Surface	74
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	10 SLOT STAINLESS STEEL KPACKER JOHNSON	74	78

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	10	

9. Static Water Level
49 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 16 GP M for 24 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		08-22-2003
Drill Rig Operator	Lic or Reg #	Date Signed
MJ		08-22-2003

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Downspout/Yard Hydrant		20

Comment:

Created On: 10-08-2003 Updated On: 05-07-2020 Review Status: