Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RE489

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BONIKOWSKE, WILLIAM	Phone #: (715)258-7504
Mailing Address: N2394 E MINER DR	
City: WAUPACA	State: WI Zip Code: 54981
County: Waupaca	Co. Permit #:
Notification #	Completed: 08-16-2003
Well Constructor (Business Name): MICHAEL JOHNSON	Lic. #: 545
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: OGDENSBURG WELL DRILLING OGDENSBURG WI 54962-9704	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 8	

1. Well Location

Town of DAYTON	Fire # (if avail.): N2394
Street Address or Road Name and Number: N2394 E MINER DR	
Subdivision Name	Lot # / Block #
Latitude / Longitude in Decimal Degree (DD): 44.3266 °N -89.1621 °W	Method Code: GCD013
SW NW or Govt Lot #	Section: 3 Township: 21 N Range: 11 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	10
6	10	52

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia... No
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? 10depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	-	I	-	BLACK TOPSOIL	Surface	1
T	S	I	M	SANDY LOAM CAVING BROWN SOFT	1	5
R	Q	Z	C	CLAY SAND & GRAVEL NONCAVING RED HARD	5	10
T	W	S	S	MED SAND CAVING BROWN SOFT	10	38
I	W	Y	S	COARSE SAND & GRAVEL CAVING WHITE SOFT	38	52

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW SAWHILL T&C R&D ASTMA53 19.45#/FT	Surface	48
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	10 SLOT STAINLESS STEEL JOHNSON KPACKER	48	52

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	10	

9. Static Water Level

7 ft. below ground surface

10. Pump Test

Pumping level 9 ft. below surface

Pumping at 16 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

17 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		08-22-2003
Drill Rig Operator	Lic or Reg #	Date Signed
MJ		08-22-2003

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		18	Downspout/Yard Hydrant		35
			Sewer - Building Sanitary		48

Comment:

Created On: 10-08-2003 Updated On: 05-08-2020 Review Status: