

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RE489		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BONIKOWSKE, WILLIAM						Phone # (715)258-7504		1. Well Location				Fire # (if avail.)			
Mailing Address N2394 E MINER DR						Town of DAYTON						N2394			
City WAUPACA						State WI		Zip Code 54981				Street Address or Road Name and Number N2394 E MINER DR			
County Waupaca		Co. Permit #		Notification #		Completed 08-16-2003		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) MICHAEL JOHNSON				Lic. # 545		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3266 °N -89.1621 °W				Method Code GCD013	
Address OGDENSBURG WELL DRILLING OGDENSBURG WI 54962-9704				Well Plan Approval #				SW NW Section Township Range or Govt Lot # 3 21 N 11 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 8		Hicap Well ? No		Hicap Property ? No		Hicap Potable ?					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 10			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... <u>No</u> Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 10depth ft. (If NO explain on back side)												
6 10 52															
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.) To (ft.)							
K - I -				BLACK TOPSOIL				Surface		1					
T S I M				SANDY LOAM CAVING BROWN SOFT				1		5					
R Q Z C				CLAY SAND & GRAVEL NONCAVING RED HARD				5		10					
T W S S				MED SAND CAVING BROWN SOFT				10		38					
I W Y S				COARSE SAND & GRAVEL CAVING WHITE SOFT				38		52					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)									
6		NEW SAWHILL T&C R&D ASTMA53 19.45#/FT				Surface		48							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)									
6		10 SLOT STAINLESS STEEL JOHNSON KPACKER				48		52							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.) To (ft.)		# Sacks Cement									
CLAY SLURRY				Surface		10									
9. Static Water Level															
7 ft. below ground surface															
10. Pump Test															
Pumping level 9 ft. below surface															
Pumping at 16 GP M for 24 Hrs.															
Pumping Method ?															
11. Well Is															
17 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
MJ				08-22-2003											
Drill Rig Operator				Lic or Reg #		Date Signed									
MJ				08-22-2003											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		18	Downspout/Yard Hydrant		35
			Sewer - Building Sanitary		48

Comment:

Created On: 10-08-2003

Updated On: 05-08-2020

Review Status: