Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RE490

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LANTZ, CARLO			Phone #: (715)467-3249
Mailing Address: 682 N MAIN ST			
City: SCANDINAVIA	State: WI	Zip Code: 54977	
County: Waupaca	Co. Permit #:	Notification #:	Completed: 08-11-2003

Well Constructor (Business Name): MICHAEL JOHNSON	Lic. #: 545	Facility ID # (Public Wells):	
Address: OGDENSBURG WELL DRILLING OGDENSBURG WI 54962-9704		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 8	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Village of SCANDINAVIA

Fire # (if avail.): 680

Street Address or Road Name and Number: 680 OAK ST

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 44.4641 °N -89.1479 °W			Method Code: GCD013
SE SE or Govt Lot #	Section: 15	Township: 23 N	Range: 11 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	10
6	10	38

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia... No
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? 10depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K - I -	BLACK TOPSOIL	Surface	1
T Q S S	MED SAND CAVING BROWNSOFT	1	16
G V Z -	CLAY GRAVEL NONCAVING GREY HARD	16	22
I Q Y S	MED SAND & GRAVEL CAVING WHITE	22	38

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW SAWHILL T&C R&D ASTMA53 19.45#/FT	Surface	34
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	10 SLOT STAINLESS STEEL JOHNSON K PACKER	34	38

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	10	

9. Static Water Level
14 ft. below ground surface

10. Pump Test
Pumping level 16 ft. below surface
Pumping at 16 GP M for 24 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		08-22-2003
Drill Rig Operator	Lic or Reg #	Date Signed
MJ		08-22-2003

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		46	Downspout/Yard Hydrant		27
Building Overhang		12	Sewer - Building Sanitary		46

Comment:

Created On: 10-08-2003 Updated On: 05-08-2020 Review Status: