

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RE796		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner TUTEWOHL, RICK Phone # (651)380-5749						1. Well Location				Fire # (if avail.)		
Mailing Address N4863 1169TH ST						Town of OAK GROVE				N4863		
City PRESCOTT State WI Zip Code 54021						Street Address or Road Name and Number N4863 1169TH ST						
County Pierce		Co. Permit #		Notification # 6534723901		Completed 10-05-2016		Subdivision Name DENLYN SECOND		Lot # 36	Block #	
Well Constructor (Business Name) PAUL E CARLSON				Lic. # 6061	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.7164 °N -92.721 °W		Method Code GCD013			
Address CARLSON WELL DRLG INC HASTINGS MN 55033				Well Plan Approval #		NE NE	Section 30	Township 26 N	Range 19 W			
				Approval Date (mm-dd-yyyy)		or Govt Lot #	30	26 N	19 W			
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method						8. Geology						
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole Lower Open Bedrock			Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)	To (ft.)	
8	Surface	197	Yes Rotary - Mud Circulation No			T	S	S	-	SAND, BROWN, SOFT	Surface	180
4	197	205	Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)			T	M	G	-	MED GRAVEL, BROWN, SOFT	180	192
						T	A	G	-	COARSE GRAVEL, BROWN, MED	192	205
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is		
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)	19 ft. below ground surface				24 in. above grade		
4	IPSCO ASTM A53 GRB WELDED			Surface	197	10. Pump Test				Developed ? Yes		
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)	Pumping level 142 ft. below surface				Disinfected ? Yes		
2	STAINLESS STEEL 15 SLOT			197	205	Pumping at 10 GP M for 2 Hrs.				Capped ? Yes		
7. Grout or Other Sealing Material						Pumping Method ?						
Method BENTONITE CIRCULATION						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NONE						
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement								
BENTONITE		Surface	197	7 S								
						13. Constructor / Supervisory Driller		Lic #	Date Signed			
						PC			10-20-2016			
						Drill Rig Operator		Lic or Reg #	Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		105	Sewer - Building Sanitary		72
Building Overhang		70	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 11-14-2016

Updated On: 06-08-2020

Review Status: