Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RE796

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TUTEWOHL, RICK	Phone #: (651)380-5749
Mailing Address: N4863 1169TH ST	
City: PRESCOTT	State: WI — Zip Code: 54021

County	Co. Permit #	Notification #	Completed
Pierce		6534723901	10-05-2016

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
PAUL E CARLSON	6061	

Address: CARLSON WELL DRLG INC
HASTINGS MN 55033

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.1

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of OAK GROVE

Fire # (if avail.): N4863

Street Address or Road Name and Number: N4863 1169TH ST

Subdivision Name	Lot #	Block #
DENLYN SECOND	36	

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.7164 °N -92.721 °W	GCD013

NE NE or Govt Lot #	Section	Township	Range
	30	26 N	19 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	197
4	197	205

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S S -	SAND, BROWN, SOFT	Surface	180
T M G -	MED GRAVEL, BROWN, SOFT	180	192
T A G -	COARSE GRAVEL, BROWN, MED	192	205

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	IPSCO ASTM A53 GRB WELDED	Surface	197
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	STAINLESS STEEL 15 SLOT	197	205

7. Grout or Other Sealing Material

Method: BENTONITE CIRCULATION

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	197	7 S

9. Static Water Level
19 ft. below ground surface

10. Pump Test
Pumping level 142 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
PC		10-20-2016
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		105	Sewer - Building Sanitary		72
Building Overhang		70	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 11-14-2016 Updated On: 06-08-2020 Review Status: