Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RE798

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KARIESCH, RYAN & ERICA	Phone #: (715)497-2644
Mailing Address: N5407 1220TH ST	
City: PRESCOTT	State: WI Zip Code: 54021
County: Pierce	Co. Permit #:
Notification #: 6607911101	Completed: 03-15-2017
Well Constructor (Business Name): PAUL E CARLSON	Lic. #: 6061
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: CARLSON WELL DRLG INC HASTINGS MN 55033	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.8	

1. Well Location

Town of OAK GROVE	Fire # (if avail.): N5407
Street Address or Road Name and Number: N5407 1220TH ST	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 44.7397 °N -92.7527 °W	Method Code: GCD013
NE SW or Govt Lot #:	Section: 13 Township: 26 N Range: 20 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	61
6	61	320

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes Rotary - Air & Foam ..... Yes
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	C	-	CLAY, BROWN, NONCAVING	Surface	6
T	H	L	-	LIMESTONE, BROWN, HARD	6	250
T	S	N	-	SANDSTONE, BROWN, SOFT	250	320

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO ASTM A53 GR B WELDED	Surface	61
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

212 ft. below ground surface

10. Pump Test

Pumping level 223 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMMIE-PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	61	13 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE AT SITE, NEW CONST.

13. Constructor / Supervisory Driller	Lic #	Date Signed
PC		03-20-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95
Building Overhang		8

Type	Qualifier	Distance
Sewer - Building Sanitary		42
Septic or Holding, or POWTS Tank		55

Comment:

Created On: 05-08-2017 Updated On: 06-08-2020 Review Status: