

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RE798		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner KARIESCH, RYAN & ERICA						Phone # (715)497-2644		1. Well Location				Fire # (if avail.)													
Mailing Address N5407 1220TH ST						Town of OAK GROVE						N5407													
City PRESCOTT						State WI		Zip Code 54021				Street Address or Road Name and Number N5407 1220TH ST													
County Pierce		Co. Permit #		Notification # 6607911101		Completed 03-15-2017		Subdivision Name				Lot #		Block #											
Well Constructor (Business Name) PAUL E CARLSON						Lic. # 6061		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7397 °N -92.7527 °W				Method Code GCD013									
Address CARLSON WELL DRLG INC HASTINGS MN 55033						Well Plan Approval #		NE SW		Section 13		Township 26 N		Range 20 W											
Approval Date (mm-dd-yyyy)						2. Well Type New Well																			
Hicap Permanent Well #						Common Well #		Specific Capacity 1.8				of previous unique well #				constructed in									
3. Well serves 1 # of						Hicap Well ? No		Reason for replaced or reconstructed well ?																	
Private, potable						Hicap Property ? No		Construction Type Drilled																	
Heat Exchange ___ # of drillholes						Hicap Potable ?		Reason for replaced or reconstructed well ?																	
4. Potential Contamination Sources - ON REVERSE SIDE														8. Geology											
5. Drillhole Dimensions and Construction Method														Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole						Lower Open Bedrock													
10		Surface		61		Rotary - Mud Circulation						Rotary - Air													
6		61		320		Rotary - Air & Foam						Drill-Through Casing Hammer													
Yes						Reverse Rotary						Cable-tool Bit ___ in. dia...													
Dual Rotary						Temp. Outer Casing ___ in. dia						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		212 ft. below ground surface				18 in. above grade											
6		IPSO ASTM A53 GR B WELDED				Surface		61		10. Pump Test				Developed ? Yes											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 223 ft. below surface				Disinfected ? Yes											
Pumping at 20 GP M for 2 Hrs.		Pumping Method ?				Capped ? Yes				Filled & Sealed Well(s) as needed?				No											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?											
Method TREMMIE-PUMPED														NONE AT SITE, NEW CONST.											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						13. Constructor / Supervisory Driller				Lic #		Date Signed					
NEAT CEMENT				Surface		61		13 S						PC				03-20-2017							
Drill Rig Operator				Lic or Reg #		Date Signed						Date Signed				Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		95	Sewer - Building Sanitary		42
Building Overhang		8	Septic or Holding, or POWTS Tank		55

Comment:

Created On: 05-08-2017

Updated On: 06-08-2020

Review Status: