

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RE799		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner LARSON, MARK						Phone # (612)987-6500		1. Well Location				Fire # (if avail.)	
Mailing Address N7471 1073RD ST						Town of EAST CLIFTON						Street Address or Road Name and Number W11126 748TH AVE RIVER FALLS	
City RIVER FALLS		State WI		Zip Code 54022		Subdivision Name				Lot #		Block #	
County Pierce		Co. Permit #		Notification # 6935799401		Completed 09-27-2017		Latitude / Longitude in Decimal Degree (DD) 44.8116 °N -92.6913 °W				Method Code GCD013	
Well Constructor (Business Name) PAUL E CARLSON				Lic. # 6061		Facility ID # (Public Wells)		SE NW Section Township Range or Govt Lot # 21 27 N 19 W		2. Well Type New Well			
Address CARLSON WELL DRLG INC HASTINGS MN 55033				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
10 Surface 61			Rotary - Mud Circulation										
6 61 285			Yes Rotary - Air Yes										
			Rotary - Air & Foam										
			Drill-Through Casing Hammer										
			Reverse Rotary										
			Cable-tool Bit ___ in. dia...										
			Dual Rotary										
			Temp. Outer Casing ___ in. dia										
			Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
T V C -				CLAY, BROWN, NONCAVING				Surface		25			
T S N -				SANDSTONE, BROWN, SOFT				25		145			
T H L -				LIMESTONE, BROWN, HARD				145		285			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		IPSCO ASTM A53 GRADE B WELDED				Surface		61					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method TREMIE-PUMPED													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT		Surface		61		19 S							
9. Static Water Level													
217 ft. below ground surface													
10. Pump Test													
Pumping level 225 ft. below surface													
Pumping at 10 GP M for 2 Hrs.													
Pumping Method ?													
11. Well Is													
18 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? No													
NONE-NEW CONSTRUCTION													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
PC								09-27-2017					
Drill Rig Operator						Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		30	Sewer - Building Sanitary		55
Foundation Drain to Clearwater		60	Septic or Holding, or POWTS Tank		140

Comment:

Created On: 10-18-2017

Updated On: 06-08-2020

Review Status: