

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RE800		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner WOLF, STEVE						Phone # (612)221-3793		1. Well Location				Fire # (if avail.)	
Mailing Address 19070 TOWERING OAKS TRL						Town of CLIFTON						W1277	
City PRIOR LAKE						State MN		Zip Code 55372				Street Address or Road Name and Number	
W12771 735TH AVE RIVER FALLS						Subdivision Name				Lot #		Block #	
County Pierce		Co. Permit #		Notification # 6992331701		Completed 11-30-2017		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) PAUL E CARLSON				Lic. # 6061		Facility ID # (Public Wells)				44.8109 °N -92.7738 °W		GCD013	
Address CARLSON WELL DRLG INC HASTINGS MN 55033				Well Plan Approval #		NW SE		Section 23		Township 27 N		Range 20 W	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 4		2. Well Type New Well				of previous unique well # constructed in			
3. Well serves 1 # of Private, potable						Hicap Well ? No		Reason for replaced or reconstructed well ?					
Heat Exchange ___ # of drillholes						Hicap Property ? No		Construction Type Drilled					
Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
10		Surface		208		Yes Rotary - Mud Circulation				No			
6		208		225		Rotary - Air							
						No Rotary - Air & Foam				Yes			
						Drill-Through Casing Hammer							
						Reverse Rotary							
						Cable-tool Bit ___ in. dia...							
						Dual Rotary							
						Temp. Outer Casing ___ in. dia							
						Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
T	S	S	-	SAND, BROWN, SOFT				Surface		85			
G	S	C	-	CLAY, GREY, SOFT				85		145			
T	S	S	-	SAND, BROWN, SOFT				145		208			
T	H	L	-	LIMESTONE, BROWN, HARD				208		225			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		IPSCO ASTM A53 GRB WELDED				Surface		208					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method MUD CIRCULATION													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
BENTONITE				Surface		208		9 S					
9. Static Water Level													
43 ft. below ground surface													
10. Pump Test													
Pumping level 46 ft. below surface													
Pumping at 12 GP M for 2 Hrs.													
Pumping Method ?													
11. Well Is													
18 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? No													
NONE													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
PC				12-04-2017									
Drill Rig Operator				Lic or Reg #									
				Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		80	Sewer - Building Sanitary		85
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 01-22-2018

Updated On: 06-08-2020

Review Status: