Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RE800

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WOLF, STEVE	Phone #: (612)221-3793
Mailing Address: 19070 TOWERING OAKS TRL	
City: PRIOR LAKE	State: MN Zip Code: 55372
County: Pierce	Co. Permit #:
Notification #: 6992331701	Completed: 11-30-2017
Well Constructor (Business Name): PAUL E CARLSON	Lic. #: 6061
Facility ID # (Public Wells):	
Address: CARLSON WELL DRLG INC HASTINGS MN 55033	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 4	

1. Well Location

Town of CLIFTON

Fire # (if avail.): W1277

Street Address or Road Name and Number: W12771 735TH AVE RIVER FALLS

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 44.8109 °N -92.7738 °W

Method Code: GCD013

NW SE or Govt Lot #: | Section: 23 | Township: 27 N | Range: 20 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	208
6	208	225

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

No — Rotary - Air & Foam ..... — Yes

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S S -	SAND, BROWN, SOFT	Surface	85
G S C -	CLAY, GREY, SOFT	85	145
T S S -	SAND, BROWN, SOFT	145	208
T H L -	LIMESTONE, BROWN, HARD	208	225

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO ASTM A53 GRB WELDED	Surface	208
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MUD CIRCULATION

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	208	9 S

9. Static Water Level

43 ft. below ground surface

10. Pump Test

Pumping level 46 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
PC		12-04-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		80	Sewer - Building Sanitary		85
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 01-22-2018 Updated On: 06-08-2020 Review Status: