Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RF426

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ZURN, CHARLOTTE			Phone #: (262)523-4263
Mailing Address: N22 W24099 CLOISTER			
City: PEWAUKEE	State: WI	Zip Code: 53072	
County: Adams	Co. Permit #:	Notification #:	Completed: 03-10-2005

Well Constructor (Business Name): TIMOTHY D DOLATA	Lic. #: 5522	Facility ID # (Public Wells):
Address: TIM DOLATA SEPTIC & WELL SERVICES LLC NEW LISBON WI 53950		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.6

1. Well Location

Town of PRESTON

Fire # (if avail.): 1389

Street Address or Road Name and Number: 1389 13TH DR

Subdivision Name: CSM 3	Lot #: 4	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.0542 °N -89.8243 °W			Method Code: GCD013
SW SE or Govt Lot #:	Section: 6	Township: 18 N	Range: 6 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: WELL OLD & SLOW PRODUCER

Construction Type: Jetted

3. Well serves # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	41
1.25	41	43

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	-	S	-	YELLOW SAND	Surface	10
I	N	S	-	FINE WHITE SAND	10	20
G	-	X	-	GRAY CLAY/SAND	20	30
I	A	Y	-	COARSE WHITE SAND/GRAVEL	30	43

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	SAWHILL R&D .154 WALL ASTM A589 T&C	Surface	41
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.25	JOHNSON STAINLESS 7 SLOT	41	43

7. Grout or Other Sealing Material

Method DRILL CUTTINGS

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JD		03-25-2005
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TD		03-25-2005

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Overhang		3
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 04-26-2005 Updated On: 05-04-2020 Review Status: