

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RF426		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner ZURN, CHARLOTTE						Phone # (262)523-4263		1. Well Location				Fire # (if avail.)					
Mailing Address N22 W24099 CLOISTER						Town of PRESTON						1389					
City PEWAUKEE						State WI		Zip Code 53072				Street Address or Road Name and Number					
County Adams						Co. Permit #		Notification #		Completed 03-10-2005		Subdivision Name CSM 3		Lot # 4		Block #	
Well Constructor (Business Name) TIMOTHY D DOLATA						Lic. # 5522		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0542 °N -89.8243 °W		Method Code GCD013			
Address TIM DOLATA SEPTIC & WELL SERVICES LLC NEW LISBON WI 53950						Well Plan Approval #				SW SE Section Township Range or Govt Lot # 6 18 N 6 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? WELL OLD & SLOW PRODUCER					
						Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6				Construction Type Jetted							
3. Well serves # of Private, potable						Hicap Well ? No											
Heat Exchange ___ # of drillholes						Hicap Property ? No											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
2		Surface		41		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											
1.25		41		43													
8. Geology																	
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)									
Y	-	S	-	YELLOW SAND		Surface		10									
I	N	S	-	FINE WHITE SAND		10		20									
G	-	X	-	GRAY CLAY/SAND		20		30									
I	A	Y	-	COARSE WHITE SAND/GRAVEL		30		43									
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
2		SAWHILL R&D .154 WALL ASTM A589 T&C				Surface		41									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
1.25		JOHNSON STAINLESS 7 SLOT				41		43									
7. Grout or Other Sealing Material																	
Method DRILL CUTTINGS																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
				Surface													
9. Static Water Level																	
12 ft. below ground surface																	
10. Pump Test																	
Pumping level 30 ft. below surface																	
Pumping at 10 GP M for 1 Hrs.																	
Pumping Method ?																	
11. Well Is																	
12 in. above grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed? Yes																	
13. Constructor / Supervisory Driller																	
JD				Lic #		Date Signed											
JD						03-25-2005											
Drill Rig Operator																	
TD				Lic or Reg #		Date Signed											
TD						03-25-2005											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		3	Septic or Holding, or POWTS Tank		45
			POWTS dispersal component (soil absorption unit or mound)		60

Comment:

Created On: 04-26-2005

Updated On: 05-04-2020

Review Status: