Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RF437

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PEASE, DONNA			Phone #
Mailing Address: 5281 STATE RD 50			
City: DELAVAN	State: WI	Zip Code: 53115	
County: Adams	Co. Permit #:	Notification #: 20198272	Completed: 07-18-2005

1. Well Location

Fire # (if avail.):

Town of PRESTON

Street Address or Road Name and Number: 1145 HWY 21

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
TIMOTHY D DOLATA	5522	

Latitude / Longitude in Decimal Degree (DD): 44.02461 °N -89.80722 °W

Method Code: GPS008

Well Plan Approval #:

NW or Govt Lot #	NE	Section	Township	Range
		20	18 N	6 E

Address: TIM DOLATA SEPTIC & WELL SERVICES LLC
NEW LISBON WI 53950

Approval Date (mm-dd-yyyy):

2. Well Type Replacement

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity

Reason for replaced or reconstructed well ?

OLD WELL NO LONGER PRODU

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	63
1.25	63	66

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	-	S	-	YELLOW SAND	Surface	10
G	-	C	-	GRAY CLAY	10	30
I	N	S	-	FINE WHITE SAND	30	45
I	-	Y	-	WHITE SAND/GRAVEL	45	66

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	SAWHILL R&D .154 WALL ASTM A584 T&C	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	JOHNSON STAINLESS 7 SLOT	63	66

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level _____ ft. below surface

Pumping at _____ GP for _____ Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BENSEAL

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

OLD WELL PULLED NEW WELL NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
TD		07-18-2005
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		4
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 08-02-2005 Updated On: 08-25-2022 Review Status: