Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RG118

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KLEPEL, CAROL	Phone #: (262)862-2149
Mailing Address: 10449 368TH AVE	
City: TREVOR	State: WI — Zip Code: 53179
County: Kenosha	Co. Permit #: — Notification #: — Completed: 08-19-2003
Well Constructor (Business Name): JOHN D KRIZAN JR	Lic. #: 571 — Facility ID # (Public Wells):
Address: KRIZAN WELL DRLG & PUMP, UNION GROVE WI 53182-9659	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.8

1. Well Location

Town of SALEM

Fire # (if avail.):

Street Address or Road Name and Number: 10449 268TH AVE

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 42.5225 °N -88.1323 °W — Method Code: GCD013

SW SE or Govt Lot #: — Section: 28 — Township: 1 N — Range: 20 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: GET OFF SHARED WELL

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	180

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	-	C	-	YELLOW CLAY	Surface	10
U	-	C	-	BLUE CLAY	10	60
-	-	Y	-	SAND & GRAVEL	60	65
U	-	C	G	STONEY BLUE CLAY	65	150
-	-	P	-	HARDPAN	150	173
-	-	L	-	LIMESOTNE	173	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO USA ASTM A53BE 6.625X 280 EL WELDED	Surface	173
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 15 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

26 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 MESH BENTONITE	Surface	173	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE THERE

13. Constructor / Supervisory Driller	Lic #	Date Signed
WM		09-02-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		13

Comment:

Created On: 01-07-2004 Updated On: 08-23-2019 Review Status: