

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RG118		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner KLEPEL, CAROL						Phone # (262)862-2149		1. Well Location				Fire # (if avail.)					
Mailing Address 10449 368TH AVE						Town of SALEM											
City TREVOR						State WI		Zip Code 53179									
County Kenosha		Co. Permit #		Notification #		Completed 08-19-2003		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) JOHN D KRIZAN JR				Lic. # 571		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.5225 °N -88.1323 °W							
Address KRIZAN WELL DRLG & PUMP UNION GROVE WI 53182-9659				Well Plan Approval #		SW SE		Section 28		Township 1 N		Range 20 E					
				Approval Date (mm-dd-yyyy)		Method Code GCD013											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.8		2. Well Type New Well				of previous unique well # constructed in							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Reason for replaced or reconstructed well ?				GET OFF SHARED WELL							
Heat Exchange ___ # of drillholes				Hicap Property ? No		Hicap Potable ?				Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) 6		From (ft.) Surface		To (ft.) 180		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)	
						Rotary - Mud Circulation						Y - C -		YELLOW CLAY		Surface 10	
						Rotary - Air						U - C -		BLUE CLAY		10 60	
						Rotary - Air & Foam						- - Y -		SAND & GRAVEL		60 65	
						<u>Yes</u> Drill-Through Casing Hammer						U - C G		STONEY BLUE CLAY		65 150	
						Reverse Rotary						- - P -		HARDPAN		150 173	
						Cable-tool Bit ___ in. dia...						- - L -		LIMESOTNE		173 180	
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.) 6		Material, Weight, Specification IPSCO USA ASTM A53BE 6.625X 280 EL WELDED				From (ft.) Surface		To (ft.) 173		60 ft. below ground surface				26 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				Developed ? Yes			
										Pumping level 80 ft. below surface				Disinfected ? Yes			
										Pumping at 15 GP M for 24 Hrs.				Capped ? Yes			
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method MOUNDED																	
Kind of Sealing Material #8 MESH BENTONITE				From (ft.) Surface		To (ft.) 173		# Sacks Cement		Filled & Sealed Well(s) as needed?				No			
												NONE THERE					
13. Constructor / Supervisory Driller								Lic #		Date Signed							
WM										09-02-2003							
Drill Rig Operator								Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		13

Comment:

Created On: 01-07-2004

Updated On: 08-23-2019

Review Status: