Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RH233

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BODISH, DAN			Phone #: (715)796-5691
Mailing Address: 1727 CO RD J			
City: HAMMOND	State: WI	Zip Code: 54015	
County: St. Croix	Co. Permit #:	Notification #:	Completed: 08-25-2003

Well Constructor (Business Name): ROGER BEECROFT	Lic. #: 182	Facility ID # (Public Wells):	
Address: ROGERS WELL DRILLING SHELL LAKE WI 54871-9801		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.8	

1. Well Location

Town of HAMMOND

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NW NW or Govt Lot #:	Section: 33	Township: 29 N	Range: 17 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	46
6	46	72

Upper Enlarged Drillhole: Yes

Lower Open Bedrock: No

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	8
-	-	C	S	SANDYCLAY	8	15
		C		CLAY	15	42
-	-	L	-	LIMESTONE	42	72

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL 18.97#/FT IPSCO WELDED	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

34 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
AQUA GROUT BENSEAL	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		08-27-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 10-10-2003 Updated On: 10-10-2003 Review Status: