

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RH245		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner HOLSTERN, RON						Phone # (715)822-3205		1. Well Location				Fire # (if avail.)							
Mailing Address PO BOX 4						Town of LAKE LAND													
City BARRONETT						State WI		Zip Code 54813											
County Barron		Co. Permit #		Notification #		Completed 09-19-2003		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) BEECROFT JEREMY WELL DR LG & PUMP REP				Lic. # 6458		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address W8203 CO HWY A SPOONER WI 54801				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 18 36 N 13 W		2. Well Type New Well				of previous unique well # constructed in							
Hicap Permanent Well #		Common Well #		Specific Capacity 1.3		Reason for replaced or reconstructed well ?													
3. Well serves 1 # of Private, potable						Hicap Well ? No													
Heat Exchange ___ # of drillholes						Hicap Property ? No													
						Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.75		Surface		76		Yes Rotary - Mud Circulation No				- - Z G		GRAVELY & CLAY & BOULDERS		Surface		68			
						Rotary - Air				- - Y -		SAND & GRAVEL		68		76			
						Rotary - Air & Foam													
						Drill-Through Casing Hammer													
						Reverse Rotary													
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		25 ft. below ground surface		18 in. above grade							
5		PVC SDR 17 EAGLE SOLVENT WELD				Surface		72		10. Pump Test		Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface		Disinfected ? Yes							
5		PS STAINLESS STEEL 12				72		76		Pumping at 20 GP M for 1 Hrs.		Capped ? Yes							
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
AQUA GROUT BENSEAL				Surface															
												13. Constructor / Supervisory Driller		Lic #		Date Signed			
												RB				09-19-2003			
												Drill Rig Operator		Lic or Reg #		Date Signed			
												JR				09-25-2003			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		50
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 02-21-2005

Updated On: 02-23-2005

Review Status: