

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RH721		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner BOOKS, JERRY						Phone # (507)354-7883		1. Well Location				Fire # (if avail.)			
Mailing Address 25 SKYVIEW LN						Town of GORDON						38325			
City NEW ULM						State MN		Zip Code 56073				Street Address or Road Name and Number			
County Ashland						Co. Permit #		Notification #		Completed 09-10-2003		38325 DARROW RD			
Well Constructor (Business Name) DONALD KARNOSH						Lic. # 660		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)		Method Code			
Address KARNOSH WELL DRILLING PHILLIPS WI 54555						Well Plan Approval #		NW NW		Section 12		Township 43 N		Range 3 W	
								or Govt Lot #		12		43 N		3 W	
Hicap Permanent Well #						Common Well #		Specific Capacity		2. Well Type New Well					
3. Well serves 1 # of Private, potable						Hicap Well ? No		Hicap Property ? No		of previous unique well # constructed in					
Heat Exchange ___ # of drillholes						Hicap Potable ?		Construction Type Drilled		Reason for replaced or reconstructed well ?					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		140		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - S P				LAYERED SAND & HARD PAN				Surface		53					
- - Q -				GRANITE				53		140					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL 18.97 LB A53 WHEATLAND PE				Surface		53							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface				1 S							
9. Static Water Level															
26 ft. below ground surface															
10. Pump Test															
Pumping level 100 ft. below surface															
Pumping at 2 GP M for 2 Hrs.															
Pumping Method ?															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
DK				Lic #		Date Signed									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Privy		110
Building Overhang		18	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 10-14-2003

Updated On: 10-14-2003

Review Status: