

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RH723		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner BRUCKNER, JIM						Phone # (920)849-2683		1. Well Location				Fire # (if avail.)	
Mailing Address W3182 HICKORY HILL R						Town of GORDON							
City CHILTON						State WI		Zip Code 53014				Street Address or Road Name and Number 71626 THOLE RD	
County Ashland		Co. Permit #		Notification #		Completed 08-29-2003		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) DONALD KARNOSH				Lic. # 660		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address KARNOSH WELL DRILLING PHILLIPS WI 54555				Well Plan Approval #		NE NW		Section 12		Township 43 N		Range 3 W	
						or Govt Lot #							
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well			
										of previous unique well # constructed in			
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ?		Construction Type Drilled					
3. Well serves 1 # of				Hicap Well ? No									
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
6		Surface		200		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes			
										Type, Caving/Noncaving, Color, Hardness, etc...			
										From (ft.) To (ft.)			
										- - P G HARDPAN & ROCKS Surface 49			
										- - Q - GRANITE 49 200			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
6		STEEL 18.97 LB A53 WHEATLAND PE				Surface		49		20 ft. below ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
										18 in. above grade			
										Developed ? Yes			
										Disinfected ? Yes			
										Capped ? Yes			
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test					
GRANULAR BENTONITE		Surface				1 S		Pumping level 100 ft. below surface					
								Pumping at 0.5 GP M for 6 Hrs.					
								Pumping Method ?					
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
DK										09-22-2003			
Drill Rig Operator								Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 10-14-2003

Updated On: 10-14-2003

Review Status: