Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RI376

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KAAP, BILL	Phone #: (715)256-2763
Mailing Address: N1302 CO HWY E	
City: WAUPACA	State: WI — Zip Code: 54981
County: Waupaca	Co. Permit #: — Notification #: — Completed: 09-19-2002
Well Constructor (Business Name): STANLEY JOHNSON	Lic. #: 189 — Facility ID # (Public Wells):
Address: E 1480 RURAL RD, WAUPACA WI 54981	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.3

1. Well Location

Town of LIND	Fire # (if avail.): N1302
Street Address or Road Name and Number: CO HWY E	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:
SW SW or Govt Lot #:	Section: 18 — Township: 21 N — Range: 12 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	15
5	15	114

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....

Yes Temp. Outer Casing 10in. dia

Yes Removed? 15depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	S	-	TAN CAVING COARSE SAND	Surface	20
G	Q	Y	-	GRAY FINE CAVING SAND & GRAVEL	20	60
-	Q	G	S	CAVING GRAVEL & COBBLES	60	68
T	Q	Y	-	CAVING TAN COARSE SAND & GRAVEL	68	73
T	S	C	M	TAN SOFT SILTY CLAY	73	100
T	-	P	-	BROWN HARDPAN	100	105
T	W	S	-	CAVING TAN WATER BEARING SAND	105	114

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	ASTM A53B IPSCO T&C	Surface	111
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	STAINLESS STEEL 10 SLOT	111	114

9. Static Water Level
19 ft. below ground surface

10. Pump Test
Pumping level 54 ft. below surface
Pumping at 12 GP for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	15	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
SJ		12-18-2002
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		5
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 05-05-2003 Updated On: 05-05-2003 Review Status: