

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RI376		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner KAAP, BILL						Phone # (715)256-2763		1. Well Location				Fire # (if avail.)							
Mailing Address N1302 CO HWY E						Town of LIND						N1302							
City WAUPACA						State WI		Zip Code 54981				Street Address or Road Name and Number CO HWY E							
County Waupaca		Co. Permit #		Notification #		Completed 09-19-2002		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) STANLEY JOHNSON				Lic. # 189		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address E 1480 RURAL RD WAUPACA WI 54981				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 18 21 N 12 E		2. Well Type New Well				of previous unique well # constructed in							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		Reason for replaced or reconstructed well ?		Construction Type Drilled				Reason for replaced or reconstructed well ?							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE												5. Drillhole Dimensions and Construction Method		8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		15		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? 15depth ft. (If NO explain on back side)		T Q S - TAN CAVING COARSE SAND G Q Y - GRAY FINE CAVING SAND & GRAVEL - Q G S CAVING GRAVEL & COBBLES T Q Y - CAVING TAN COARSE SAND & GRAVEL T S C M TAN SOFT SILTY CLAY T - P - BROWN HARDPAN T W S - CAVING TAN WATER BEARING SAND		Surface		20							
5		15		114						20		60							
										60		68							
										68		73							
										73		100							
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		19 ft. below ground surface				12 in. above grade					
5		ASTM A53B IPSO T&C				Surface		111		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 54 ft. below surface				Disinfected ? Yes					
2		STAINLESS STEEL 10 SLOT				111		114		Pumping at 12 GP for 2 Hrs.				Capped ? Yes					
7. Grout or Other Sealing Material						Pumping Method ?				Filled & Sealed Well(s) as needed?									
Method						12. Notified Owner of need to fill & seal ?				13. Constructor / Supervisory Driller				Lic #		Date Signed			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		BENTONITE				SJ				12-18-2002			
		Surface		15								Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		5	Septic or Holding, or POWTS Tank		40
			POWTS dispersal component (soil absorption unit or mound)		60

Comment:

Created On: 05-05-2003

Updated On: 05-05-2003

Review Status: