

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RJ917		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner STUTZ, GARY						Phone # (608)372-5283		1. Well Location				Fire # (if avail.) 25434	
Mailing Address 315 E MILWAUKEE ST						Town of PORTLAND						Street Address or Road Name and Number CO RD X	
City TOMAH			State WI		Zip Code 54660		Subdivision Name				Lot # Block #		
County Monroe		Co. Permit #		Notification #		Completed 03-01-2003		Latitude / Longitude in Decimal Degree (DD) 43.8062 °N -90.8217 °W				Method Code GCD013	
Well Constructor (Business Name) ROY E OINES				Lic. # 280		Facility ID # (Public Wells)		NE SW Section Township Range or Govt Lot # 2 15 N 4 W		Well Plan Approval #			
Address 406 WALNUT DR HOLMEN WI 54636-9605				Approval Date (mm-dd-yyyy)		2. Well Type New Well							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled							
Private, potable				Hicap Property ? No									
Heat Exchange ____ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
8 Surface 195			Rotary - Mud Circulation										
6 195 208			Rotary - Air										
			Yes Rotary - Air & Foam Yes										
			Drill-Through Casing Hammer										
			Reverse Rotary										
			Cable-tool Bit ____ in. dia...										
			Dual Rotary										
			Temp. Outer Casing ____ in. dia										
			Removed? ____ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)				
- - C -			CLAY			Surface			12				
- - H -			SHALE			12			28				
- - N -			SANDSTONE			28			208				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		NEW P.E. BLACKSTEEL 18.95# 280 WALL WELD ASTMA53 USA WHEATLAND				Surface		195					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method PRESSURE TRIMME													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
PORTLAND NEAT CEMENT		Surface		195		37 S							
9. Static Water Level													
161 ft. below ground surface													
10. Pump Test													
Pumping level 177 ft. below surface													
Pumping at 10 GP for 1.5 Hrs.													
Pumping Method ?													
11. Well Is													
23 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
Drill Rig Operator		Lic or Reg #		Date Signed									
JS				03-01-2003									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		78	Foundation Drain to Clearwater		34
Building Drain - Sanitary		63	Sewer - Building Sanitary		60
Building Overhang		22	Septic or Holding, or POWTS Tank		31

Comment:

Created On: 05-29-2003

Updated On: 04-29-2020

Review Status: