

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RJ976		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner WEYENBERG, JIM						Phone # (715)667-3846		1. Well Location				Fire # (if avail.)									
Mailing Address 9434 320TH ST						Town of DELMAR						Street Address or Road Name and Number 95TH AVE									
City BOYD				State WI		Zip Code 54726															
County Chippewa		Co. Permit # 21475		Notification #		Completed 12-14-2002		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) JEFF HATFIELD				Lic. # 5201		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code							
Address 9180 CO HWY G STANLEY WI 54768-6014				Well Plan Approval #				°N °W		NE SW Section Township Range		2. Well Type New Well									
				Approval Date (mm-dd-yyyy)				or Govt Lot # 19 29 N 5 W													
Hicap Permanent Well #			Common Well #			Specific Capacity 0.2				Reason for replaced or reconstructed well ?											
3. Well serves 1 # of Private, potable						Hicap Well ? No															
Heat Exchange ____ # of drillholes						Hicap Property ? No				Construction Type Drilled											
Hicap Potable ?																					
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		20		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				- - C T CLAY - A Y - SAND/GRAVEL - - N - SANDROCK				Surface		30					
6		20		100										30		40					
40		100		100																	
100		100		100																	
100		100		100																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		30 ft. below ground surface				12 in. above grade							
6		STD BLACK STEEL WELDED PE .280 WALL 19.47 ASTMA53 SAWHILL				Surface		57		10. Pump Test Pumping level 80 ft. below surface Pumping at 10 GP M for 5 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No							
Method																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
CLAY SLURRY				Surface		20				13. Constructor / Supervisory Driller				Lic #		Date Signed					
														JJH		03-03-2003					
														Drill Rig Operator		Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		40	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-04-2003

Updated On: 04-04-2003

Review Status: