Well Construction Report
WISCONSIN UNIQUE WELL NUMBER RK849

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HARTL, JEFF		Phone #: (715)387-0726
Mailing Address: 9683 HWY T		
City: MARSHFIELD	State: WI	Zip Code: 54449
County: Wood	Co. Permit #:	Notification #:
Completed: 05-24-2003		

Well Constructor (Business Name): KLINE WELL & PUMP INC	Lic. #: 6010	Facility ID # (Public Wells):
Address: PO BOX 176 LOYAL WI 54446		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.1

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of RICHFIELD
Fire # (if avail.)
Street Address or Road Name and Number
Subdivision Name | Lot # | Block #
Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code

NW	NW	Section	Township	Range
or Govt Lot #		6	24 N	3 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	50.5
6	50.5	200

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	11
-	-	N	C	SANDSTONE & CLAY LAYERED	11	34
-	D	Q	-	DECOMPOSED GRANITE	34	50.5
-	-	Q	-	GRANITE	50.5	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 LB. NEW STEEL ASTM-A53B WELDED SAWHILL	Surface	50.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 5 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	50.5	7.5 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		06-17-2003
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 07-21-2003 Updated On: 07-21-2003 Review Status: