

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				RK849		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner HARTL, JEFF						Phone # (715)387-0726		1. Well Location				Fire # (if avail.)					
Mailing Address 9683 HWY T						Town of RICHFIELD											
City MARSHFIELD						State WI		Zip Code 54449									
County Wood		Co. Permit #		Notification #		Completed 05-24-2003		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) KLINE WELL & PUMP INC				Lic. # 6010		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address PO BOX 176 LOYAL WI 54446				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 6 24 N 3 E		2. Well Type New Well				of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		Reason for replaced or reconstructed well ?											
3. Well serves 1 # of Private, potable						Hicap Well ? No		Hicap Property ? No				Construction Type Drilled					
Heat Exchange ___ # of drillholes						Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.75		Surface		50.5		Rotary - Mud Circulation				- - C -		CLAY		Surface		11	
6		50.5		200		<u>Yes</u> Rotary - Air <u>Yes</u>				- - N C		SANDSTONE & CLAY LAYERED		11		34	
						Rotary - Air & Foam				- D Q -		DECOMPOSED GRANITE		34		50.5	
						Drill-Through Casing Hammer				- - Q -		GRANITE		50.5		200	
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		18 ft. below ground surface		16 in. above grade					
6		18.97 LB. NEW STEEL ASTM-A53B WELDED SAWHILL				Surface		50.5		10. Pump Test		Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 60 ft. below surface		Disinfected ? Yes					
										Pumping at 5 GP M for 2 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method PRESSURE TREMIE												Filled & Sealed Well(s) as needed?					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				NONE							
NEAT CEMENT		Surface		50.5		7.5 S											
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												DK				06-17-2003	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 07-21-2003

Updated On: 07-21-2003

Review Status: